

Approximate Location by Subsection	Water Well Driller Reports Reviewed	Range of Completed Depths (ft)	Range of Static Depths to Water (ft)	Approx. Groundwater Elevations (ft msl)	Range of Tested Yields (gpm)
10S/3W-13M	2	75 - 100	40 - 60	1,630 - 1,650	15
10S/3W-24B	1	120	60	1,630	10
10S/3W-24D	6	80 - 160	35 - 60	1,520 - 1,550	5 - 35
10S/3W-24E	5	90 - 150	35	1,470	10 - 45
10S/3W-24D/E/M	3	100 - 160	25 - 40	?	10 - 50
10S/3W-24F	1	145	45	1,500	25
10S/3W-24L	1	345	25	1,400	15
10S/3W-24M	2	60 - 150	25	1,340 - 1,400	10 - 55
10S/3W-24N	3	65 - 180	10 - 25	1,270 - 1,290	10 - 75
10S/3W-24Q	1	115			
10S/3W-25C	2	125 - 300	40 - 220	1,040 - 1,300	3 - 15
10S/3W-25D/E	1	120	50	1,190	30
Located by Section Only					
10S/3W-24	13	80 - 430	15 - 320	?	5 - 60
10S/3W-25	2	280 - 500	40 - 130	?	15
Total	43				
Range		60 - 500	10 - 320	1,040 - 1,650	3 - 75
Average		150	55	1,430	25
Median		120	40	1,470	20

Summary of Reviewed Water Well Driller's Reports

Table 29